



NOTES:

1. Use duplex receptacle computer isolation, on separate circuit when service not located in rail at all computer stations.
2. 2' x 4' (610mm x 1219mm) recessed floor. w/4 - F40 CW lamps
3. 2' x 2' (610mm x 610mm) recessed floor. w/2 - F20 CW lamps
4. 2' x 4' (610mm x 1219mm) recessed floor. w/3 - F40 CW lamps
5. 2' x 4' (610mm x 1219mm) recessed floor. w/2 - F40 CW lamps
6. Motorized Ceiling HEPA Filters, Class 10, 47 5/8" x 23 5/8" (1219mm x 609mm)

LEGEND

	Light Fixture Emergency On Power. Clinic Requires Battery Ballast		Fixture Type a ₂ (see note 3) Control Switch a ₃
	Fixture Type a ₁ (see note 2) Control Switch a		Ceiling Air Diffuser
	Fixture Type a ₁ (see note 2) Control Switch a ₃		Ceiling Air Return
	Fixture Type b ₁ (see note 5) Control Switch a		Switch Fixture a
	Fixture Type c ₁ (see note 4) Control Switch a		Switch Fixture a ₃
	Fixture Type a ₁ (see note 4) Control Switch a ₄		Switch Fixture a ₄
	Ceiling HEPA Filter (see note 6)		Ionization Smoke Detectors

MIMIMAL LAB URINALYSIS (LMUO1)

MILCARE

CEILING PLAN

DATE: 11/26/2002

12.61 NSM (136 NSF) MIN.

0 1000 2000



1:50 SCALE (MILLIMETERS)